

November 2018 revision to the NSW Service and Installation Rules

I am writing in relation to the November 2018 edition of the Service and Installation Rules of NSW (the Rules) recently revised by the Service and Installation Rules Committee. Listed below is a summary of the amendments and a copy of the Rules can be viewed on the Department's web site.

Please feel free to distribute this information further in an effort to reach as wide an audience as possible.

<https://energy.nsw.gov.au/government-and-regulation/legislative-and-regulatory-requirements/service-installation-rules>

The revised Rules may be applied now.

Should you have any further enquiries, contact your local distributor.

4.7.2 c) Selection of Rating of Meter Protection Devices

Reinsert phrase 'must be located adjacent to or incorporated in the MSB' which was accidentally omitted when revising SIRs with the separation of the Annexure for metering.

4.10 Service Neutral Links

Clarified introductory sentence to ensure service neutral link is obligatory.

5.2.2 Underground Supply from Underground Mains

Changed acceptable length of a special service to 30m from 10m. Added sentence to ensure it also complies to all other conditions of **Section 2 – Underground Services**.

8.6.13.1 Conductor Size Exception Clause

Updated worked example and accompanying table, to meet maximum acceptable voltage. Added reference to voltage as per AS 4777.