

Dear Scheme rule maker,

Regarding the rule change, Stairways, including fire-isolated stairways 5,000 A (Others), this one must be referring to the fire stair in a building. By law, the fire stair has to maintain 80 lux all the time, which means all the lights have to burn 24/7, but how come the operation hour is only 5000 hrs per year?

We did hundreds of buildings LED lighting upgrade, none of them are controlled by any switch or push button. All the lights in fire stairs are burning 24/7. Fire stair is a special part of the building safety, it's different from stairwell. As for stairwell, some old buildings without lifts, they install push delay button or switch in the stairwell. But fire-isolated stairway is fire stair.

thanks

--

Kind Regards

Daisy Shen

Accredited Certificate Provider

WBS Technology

Intelligent Technology Connecting People, Places & Things

Slough Business Park

Unit 32, 2 Slough Avenue, Silverwater NSW 2128